



Unit 6 Marble Court Business Park
Lymington Road
Torquay
TQ1 4FB
Telephone: 01803 664100
Email: doors@alldoorssw.co.uk

Job Service Report

27 October 2025

Stowford Community Centre	Job Address	Chambers Close Sidmouth EX10 9YL	Job Number	J14782
	Reference	Service		

Service for 2no Kitchen Roller Shutters.
PLEASE GET HERE BEFOR 9AM

Tasks

Staff Member	Task	Description
daren summerfield 27.10.25	stowford community centre, Sidmouth devon	Door 2, Kitchen, tube operation fire resisting roller shutter door 2340mm wide x 1530mm high, drop test on fire control signal carried out and fully successful, no fire certification plate fitted to the door
daren summerfield 27.10.25	stowford community centre, Sidmouth devon	Door 1, Kitchen tube motor fire resisting roller shutter door 2340mm wide x 1530mm high, drop test on fire control signal carried out and fully successful, no fire rating certification plate to the door,