

Fords SW Ltd Alexandria Industrial Estate Alexandria Road Sidmouth Devon EX10 9HA

EX5 4NW

Tel:

01392 882321

Mobile: 07969 834921

Email: oakwaterlabs@gmail.com

8720-23/NLDC

17th September 2024

Dear Sirs,

I acknowledge the receipt on 9th September 2024 of four specimens of water, submitted to this laboratory as representative samples of the mains water from Stowford Community Centre, Chambers Close, Sidmouth, EX10 9YL.

I have caused the required examinations to be carried out with the results shown below:-

Specimen Marked	Total viable @ 22°C (per ml)	count of bacteria @ 37°C (per ml)	Residual chlorine (mg/litre)
Main Kitchen, Hot	18	9	< 0.02
Main Kitchen, Cold	13	18	1.80
Childrens Kitchen, Hot	944 *	86	< 0.02
Childrens Kitchen, Cold	1418 *	396 *	< 0.02

^{*} Result is higher than is normally regarded as desirable.

I shall be pleased to answer any questions arising from this report, if desired.

Yours faithfully,

Nigel Cauchois