

Fords SW Ltd Alexandria Industrial Estate Alexandria Road Sidmouth Devon EX109HA

EX5 4NW

Tel:

01392 882321

Mobile: 07969 834921

Email: oakwaterlabs@gmail.com

9980-3/NLDC

3rd November 2025

Dear Sirs,

I acknowledge the receipt on 24th October 2025 of four specimens of water, submitted to this laboratory as representative samples of the mains water from Stowford Community Centre, Chambers Close, Sidmouth, EX10 9YL.

I have caused the required examinations to be carried out with the results shown below:-

Specimen Marked	Total viable @ 22°C (per ml)	count of bacteria @ 37°C (per ml)	Residual chlorine (mg/litre)
Main Kitchen, Hot	11	66	< 0.01
Main Kitchen, Cold	2	35	0.21
Childrens Kitchen, Hot	4	9	< 0.01
Childrens Kitchen, Cold	9	82	0.02

The results indicate that all four specimens were of satisfactory bacteriological quality.

I shall be pleased to answer any questions arising from this report, if desired.

Yours faithfully,

Nigel Cauchois